

NTC pentru Ianuarie 2015 _V1: licitatii lunare

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1422 MW (472 MW + 950 MW) ; 2 unitati in CNE; CEE 1200MW;
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita anulate;
- Import initial GR+MK+AL **1550MW**, import initial TR **350MW**, import initial HU **1900MW**, import initial RS **260MW**
Masuri preventive si post-avarie. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **ianuarie 2015** sunt :

NTC	01-04.01 2015	05-11.01 2015	12-14.01 2015	15-23.01 2015	24-25.01 2015	26-31.01 2015
RO=>HU	650					
HU=>RO	450		550	700		450
RO =>RS	600					
RS =>RO	300		500	550		300
RO =>BG	150					
BG =>RO	150					
RO=>UA	50					
UA =>RO	100					
RO Export	1450					
RO Import	1000 ^(2TO)		1300 ^(2TO+CI)	1500 ^(2TO+CI)		1000 ^(2TO)

- TRM export/import in interfata RO **300 MW / 400 MW** ;
- AT Rosiori 105-106% + masuri, L 110kV CET Arad-Sofronea 100% (20°C) +masuri.
- Masuri postavarie : conectarea celui de-al doilea T Oradea (2TO), 12-25.01 2015 s-a considerat conectarea CT 110kV Iernut (CI).
- Declansare L220kV Portile de Fier-Resita c1 => incarcare L220kV Portile de Fier-Resita c2 $\leq 110\%I_{nom.TC}$ (descarcare post-avarie)