

NTC ferme pentru August 2015: licitatii lunare

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap **847 MW** (380 MW + 467 MW) ; CEE 1000MW+CEF 850MW;
- Limita pe LEA400kV Portile de Fier-Djerdap **1300 A** (reglaje de **vara** la protectii in Serbia) ;
- Export initial RO **1000MW**, BG **1000MW**
- Import initial GR+MK+AL+TR **1900MW** (105MW import GR pe cablu GR-IT) , import initial RS **185MW**, import initial HU **3000MW**
- Masuri preventive si post-avarie. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **August 2015** pentru licitatii lunare sunt :

NTC	01-02.08	03-05.08	06-07.08	08-09.08	10.08	11-12.08	13-14.08	15-16.08	17.08	18-19.08	20.08	21.08	22-23.08	24.08	25-27.08	28-29.08	30.08	31.08
		Arad-C.Aradului Cernavoda-Pelicanu Mintia-A.Iulia			PF-R1						Tant-B			AT3 Mintia Brasov-Gutinas AT1 Arad				
					Isaccea-Rahman													PdF-Dj
		Djerdap-Bor AT Mukacevo Heviz-Szo.1+Heviz-Liter Em-P1+2				Bor-Nis							Djerdap-Drmno		Ern.-Ugl.			Kosovo-Uros.
														Mukacevo- Burstyn Gyor-Gabcikovo Paks-Sandorfalca Mizia-Tsarevets				
RO=>HU	700				550	700												
HU=>RO	700																	
RO =>RS	550				400	500			650			600					550	0
RS =>RO	400					350			550									0
RO =>BG	150																	
BG =>RO	300																	
RO=>UA	100				50	100						50						100
UA =>RO	150								100	50			100					150
ROexport	1500				1150	1450			1600			1500					1450	950
ROimport	1550					1500			1650	1600		1650	1650	1650^{+2TO}				1150^{+2TO}

- TRM export/import in interfata RO 200(31.08)-**300MW** / 300(31.08)-**400 MW**;
- In regimuri post-avarie: LEA 220kV Portile de Fier-Resita-Timisoara $1,2 \leq I$ termic 30° ; AT Rosiori $\leq 105\%$; LEA 110kV CET Arad-Sofronea 100% (30°);
- Masuri preventive / postavarie: - Conditionari de regim (vara 2015);
- modificare preventiva a ploturilor AT400/220kV Arad, AT400/220kV Urechesi;
- descarcare/deconectare a unor grupuri in CHE Portile de Fier I post-avarie;
- conectarea post-avarie a T Oradea in rezerva (**2TO**).

TTC ferme pentru August 2015: licitatii lunare

Valorile TTC fiabile pe granitele Romaniei in **August 2015** :

NTC	01-02.08	03-05.08	06-07.08	08-09.08	10.08	11-12.08	13-14.08	15-16.08	17.08	18-19.08	20.08	21.08	22-23.08	24.08	25-27.08	28-29.08	30.08	31.08			
RO=>HU	800				650	800															
HU=>RO	800																				
RO =>RS	650				500	600				750				700				650	0		
RS =>RO	500					450				650										0	
RO =>BG	250																				
BG =>RO	400																				
RO=>UA	200				150	200								150				200			
UA =>RO	250									200			150			200				250	
ROexport	1800				1450	1750				1900				1800				1750	1150		
ROimport	1950					1900				2050			2000			2050	2050 ^{+2TO}			1450 ^{+2TO}	

- TRM export/import in interfata RO 200(31.08)-**300MW** / 300(31.08)-**400 MW**;
- TRM export/import pe granita 100MW;
- **TTC export total in interfata RO # Suma TTC export pe granite.**