

NTC pentru luna 2014_V1 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1466-1526 MW (600-680MW +866 MW) pentru 2-1 unitati in CNE;
- Limita pe L400kV Portile de Fier-Djerdap **1300 A** (Djerdap); reglaje de **vara** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1400MW, Turcia import 350MW, HU import initial 2550MW, RS export initial 49MW.;
- Export initial RO 800MW, BG 700 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **lunie 2014** sunt :

NTC	01.06 2014	02.06 2014	03-04.06 2014	05-06.06 2014	07-08.06 2014	09-11.06 2014	12.06 2014	13.06 2014	14-15.06 2014	16-17.06 2014	18-21.06 2014	22.06 2014	23-27.06 2014	28-29.06 2014	30.06 2014
	Saj-Mu			BMare-Tihau					Arad-Sandorfalva				A.Iulia-Mintia Isaccea-Stupina		
RO=>HU	500			550				550							
HU=>RO	300	500	450	500	550	550			400	300	500	350			
RO =>RS	450						500	450	500	450					
RS =>RO	300	400	350	400	450	400			450	350	300				
RO =>BG	200														
BG =>RO	300														
RO=>UA	50														
UA =>RO	100														
ROExport	1200			1250				1300	1250	1300	1250				
ROImport	1000 ^{2TO}	1300	1200	1300	1400	1350			1400	1150 ^{2TO}	1000 ^{2TO}	1200 ^{2TO}	1050 ^{2TO}		

- TRM export/import in interfata RO **300 MW / 400 MW** ; TRM export in interfata RO+BG **300 MW**
- Limita import calculata cu cresterea deficitului in S4.
- Masuri postavarie : conectarea T Oradea in rezerva (^{2TO})