

NTC pentru Martie 2014 _V1 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1500 MW (650MW +850 MW);
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1200MW, Turcia import 500MW, HU import initial 1800MW, RS import initial 26MW.;
- Export initial RO 700MW, BG 700 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Martie 2014** sunt :

NTC	01-02.03 2014	03-04.03 2014	05-06.03 2014	07.03 2014	08-09.03 2014	10-12.03 2014	13-14.03 2014	15-16.03 2014	17-20.03 2014	21.03 2014	22-23.03 2014	24-25.03 2014	26-28.03 2014	29-30.03 2014	31.03 2014
	BucS-Pel								Mintia-SibiuS					Stup-Va	
		Kisvardia-Muk	Tiszaok-Muk					Bekescsaba-Szolnok				Ernestinovo-Pecs 1c			Stej-Gh
			Lem-Kros									Mukacevo-V.Kapusany			Mel-Bit
	Levice-R.Sobota												Varna-B		
RO=>HU	650								600					650	
HU=>RO	500	450	500	450		500		350		450	500				550
RO =>RS	650								600						
RS =>RO	400							300		400	450				
RO =>BG	125														
BG =>RO	125														
RO=>UA	50														
UA =>RO	100														
ROExport	1475								1375					1425	
ROImport	1125	1075	1125	1075		1125		875		1075	1175				1225

- TRM export/import in interfata RO **300 MW / 400 MW**
- TRM export in interfata RO+BG **300 MW**
- Limita import calculata cu cresterea deficitului in S4
- Declansare 1c 220kV Portile de Fier-Resita => $c2 \leq I_{termic} 25^\circ \& TC < 115\%$ + descarcare post-avarie