

NTC pentru Noiembrie 2014 _V2: licitatii lunare

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
 - Generatie initiala in CHE Portile de Fier si Djerdap 1517 MW (900 MW +617 MW) ; 2 unitati in CNE; CEE 1300MW +CFE 400MW;
 - Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
 - Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
 - Import initial GR+MK+AL **1450 MW** (150MW din IT),Turcia import **520 MW**, HU import initial **2350 MW**, RS import initial **326 MW**.;
 - Export initial RO **1100 MW**, BG **600 MW**
- Masuri preventive si post-avarie. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Noiembrie 2014** sunt :

NTC	01-02.11 2014	03-07.11 2014	08-09.11 2014	10.11 2014	11.11 2014	12-14.11 2014	15-16.11 2014	17-23.11 2014	24-28.11 2014	29-30.11 2014		
RO=>HU	650		700					650				a
HU=>RO	350		550									a
RO =>RS	600										a	
RS =>RO	500										a	
RO =>BG	200										a	
BG =>RO	300										a	
RO=>UA	50											
UA =>RO	100											
RO Export	1500		1550					1500				
RO Import	1250 ^{2TO}		1450 ^{2TO}									1450

- TRM export/import in interfata RO **300 MW / 400 MW** ; TRM export in interfata RO+BG **300 MW**
- Limita import calculata cu crestere (limitata) a deficitului in S4.
- AT Rosiori 105-106%+ conectarea T Oradea in rezerva (^{2TO}).