

NTC pentru Aprilie 2014 _V1 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1740 MW (840MW +900 MW);
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1150MW, Turcia import 400MW, HU import initial 1900MW, RS export initial 49MW.;
- Export initial RO 500MW, BG 700 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Aprilie 2014** sunt :

NTC	01-04.04 2014	05.04 2014	06.04 2014	07.04 2014	07-08.04 2014	09-11.04 2014	12-13.04 2014	14-16.04 2014	17-18.04 2014	19-20.04 2014	21.04 2014	22.04 2014	23-25.04 2014	26-27.04 2014	28-29.04 2014	30.04 2014	
	Bras-Dars	BraziV-Domnesti						Tantareni-Urechesti		LEA SK			Brasov-Sibiu				
	Arad-C.Aradului + Arad-Timisoara						T4 Sibiu		AT3 Arad			AT3 Arad					
	Stejaru-Gheorghieni						Dumbrava-Stejaru		Dumbrava-Stejaru			Ros-Orad					
	Stupina-Varna						Rahman-Dobrudja										
	Sajoszeged-Mukacev	Burstyn-Mukacevo	Albertirsa-ZUkrainskaia														
	Varna-Burgas			Mladost-SMitrovica			Paks-Safa Paks-Mart		Tarevet-Varna			Jagod-Krag					
	Meliti-Bitola						Melina-Tumbri					Kos-Uros Nsanta-Babaeski					
	Szolnok-Bekescsaba																
RO=>HU	600	650						600	650			600					
HU=>RO	300				550	600	500				400	550	600		300		
RO =>RS	600																
RS =>RO	250				400						300	350	400		300		
RO =>BG	150																
BG =>RO	200											150					
RO=>UA	50																
UA =>RO	100																
ROExport	1400	1450						1400	1450			1400					
ROImport	850			1250			1300	1200			1000	1150		1250	850		

- TRM export/import in interfata RO **300 MW / 350-400 MW** ; TRM export in interfata RO+BG **300 MW**
- Limita import calculata cu cresterea deficitului in S4
- Declansare 1c 220kV Portile de Fier-Resita => c2 ≤ Itermic 30°&TC<110% + descarcare post-avarie