

## NTC ferme pentru octombrie 2018: licitatii lunare\_v5

Valorile NTC fiabile pe granitele Romaniei in **octombrie 2018** pentru licitatii lunare sunt :

NTC	1-3.10	4.10	5.10	6-7.10	8-9.10	10-11.10	12.10	13-14.10	15-16.10	17-19.10	20-21.10	22.10	23.10	24.10	25.10	26.10	27-28.10	29.10	30.10	31.10	
	L400kV Nis-Sofia V	L 400 kV Djerdap-Drmno									L 400 kV Arad-Sandorfalva (RO-HU)	L 400 kV Arad-Mintia, L 400 kV Rahman-Dobrudja (RO-BG)						L 400 kV Mintia-Sibiu Sud, L 220 kV Tihau-Cluj Floresti			
	L 400 kV Stupina-Varna (RO-BG)					L 400 kV Rosiori-Mukacevo (RO-UA)					L 220 kV Baia Mare-Tihau										
	L 220 kV Mintia-Timisoara			L 220 kV Mintia-Timisoara																	
RO=>HU	450	500	550	550	600	550	500	550	500	550	500	550	650	450							
HU=>RO	500									700		500				700	500				
RO=>RS	400	400	500	400	500	350	450	400	500	250											
RS=>RO	350									800		400				800	450				
RO=>BG	350										250										
BG=>RO	400										300										
RO=>UA	0						0	50	0	50	0	50	0								
UA=>RO	0						300		0				300	0							
RO export	1200	1250	1400	1300	1450	1400	1200	1400	1300	1150	1250	1200	1450	950 <sup>(HT)</sup>							
RO import	1250 <sup>(VrS,M,S4,pA,pU,pTA)</sup>									2200 <sup>(VrS)</sup>		1200 <sup>(VrS,M,S4,pA,pU,pTA)</sup>				2100 <sup>(VrS)</sup>	1250 <sup>(VrS,M,S4,pA,pU,pTA)</sup>				

- TRM export / import in interfata RO 300 MW / 400 MW, cu exceptia intervalelor in care sunt retrase liniile de interconexiune cu RS si UA, cazuri in care TRM in interfata RO este 200 MW / 300 MW;