

## NTC pentru Aprilie 2012 \_ V2 :

### Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1800MW (900MW +900MW);
- Limita pe L400kV Portile de Fier-Djerdap 1600 A ( Pdfier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1100MW, Turcia 50MW, HU 1065MW, RS 190MW.;
- Export initial RO 600MW, BG 400 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Aprilie 2012** sunt :

| NTC       | 01.04<br>2012 | 02-06.04<br>2012  | 07-08.04<br>2012              | 09-12.04<br>2012 | 13-15.04<br>2012 | 16-20.04<br>2012 | 21-22.04<br>2012         | 23-26.04<br>2012 | 27-29.04<br>2012 | 30.04<br>2012 |
|-----------|---------------|---|-------------------------------|------------------|------------------|------------------|--------------------------|------------------|------------------|---------------|
|           |               | Arad-Timis,<br>Brasov-Gutin,<br>Burst.-Muk.<br>Beograd-Obr. | + Arad-CArad<br>Albert.-ZUkr. |                  | Isaccoea-Rahm    |                  | Arad-Sala<br>Domn.-Brazi | Tant.-Urec.      | Stejaru-Gheo.    |               |
| RO=>HU    | 400           |   |                               |                  |                  |                  |                          |                  |                  |               |
| HU=>RO    | 300           |   |                               |                  |                  |                  | 350                      |                  |                  |               |
| RO =>RS   | 600           |   |                               |                  | 650              |                  |                          |                  |                  |               |
| RS =>RO   | 300           |   |                               |                  |                  |                  |                          |                  |                  |               |
| RO =>BG   | 300           |   |                               |                  |                  |                  |                          |                  |                  |               |
| BG =>RO   | 250           |   |                               |                  |                  |                  |                          | 200              |                  |               |
| RO=>UA    | 50            |   |                               |                  |                  |                  |                          |                  |                  |               |
| LUA =>RO  | 100           |   |                               |                  |                  |                  |                          |                  |                  |               |
| RO Export | 1350          |   |                               |                  | 1400             |                  |                          |                  |                  |               |
| RO Import | 950           |   |                               |                  |                  |                  | 1000                     | 950              |                  |               |

- TRM export/import in interfata RO 300 MW / 400 MW

- TRM export in interfata RO+BG 300 MW

**Limite**

**Export :**

- dec. LEA 400kV Tantareni-Kozlodui -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
  - dec. LEA 400kV Nis-Sofia V -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
  - dec. LEA 400kV Djerdap-Bor -> 100-102% TC LEA 400kV Tantareni-Kozlodui
- 02-12.04**
- dec. LEA 400kV Arad-Mintia -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
- 23-27.04+40.04**
- dec. AT2 220/110kV Timisoara -> 100-105% TC LEA 220kV Timisoara-Sacalaz

**Import**

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori