

NTC pentru Decembrie 2012_V3z :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1427MW (700MW +727MW);
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1200MW ,Turcia import 50MW , HU import initial 1050MW , RS import initial 720MW.;
- Export initial RO 500MW, BG 650 MW
- Masuri preventive si post-event. Schimburii prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Decembrie 2012** sunt :

NTC	01-02.12 2012	03-04.12 2012	05-06.12 2012	07.12 2012	08-09.12 2012	10-13.12 2012	14-16.12 2012	17.12 2012	18.12 2012	19-20.12 2012	21-22.12 2012	23.12 2012	24-31.12 2012
	Isaccea-Varna G.Ial-L.Sar	A.Iulia-Cluj F. Lemesani-V.Kapusany	Iernut-Sibiu*	Nosovice-Varin	LEA SK								
RO=>HU	500	550											
HU=>RO	250	350			200				250				
RO =>RS	500		550										
RS =>RO	250	300			150				200				
RO =>BG	250												
BG =>RO	250							350					300
RO=>UA	50												
UA =>RO	100												
ROExport	1300	1350	1400										
ROImport	850	1000			700			800	900				850

- TRM export/import in interfata RO 300 MW / 400 MW

- TRM export in interfata RO+BG 300 MW

* S4 ≤ 630-700MW

Limite

Export :

- dec. LEA 400kV Tantareni-Kozlodui -> 100-102% LEA 400kV Portile de Fier-Djerdap (Djerdap)
- dec. LEA 400kV Nis-Sofia V -> 100-102% LEA 400kV Portile de Fier-Djerdap

Import

01-07.12+18-31.12

- dec. LEA 400kV Rosiori-Gadalin -> 100-103%AT 400/220kV Rosiori +**S4≤1000MW**
- dec. AT 400/220kV Iernut -> 100-103%AT 400/220kV Rosiori

08-17-.12

- dec. LEA 400kV Rosiori-Mukacevo -> LEA 110kV C.Arad-Ch.Cris 110-112% (Itermic 20°)
+**S4≤ 630-700MW**: redispecerizare preventiva CTE Iernut 0->170MW+CHE Mariselu 70->210MW (sau CHE Mariselu 70->140MW+CHE Galceag 0->70MW)