

NTC pentru Martie 2012_V0 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1600MW (700MW +900MW);
- Limita pe L400kV Portile de Fier-Djerdap 1600 A (PdFier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1100MW, Turcia import 40MW, HU import initial 720MW, RS import initial 210MW.;
- Export initial RO 400MW, BG 400 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe grantele Romaniei in **Martie 2012** sunt :

NTC	01-04.03 2012	05-11.03 2012	12-14.03 2012	15-18.03 2012	19-23.03 2012	24-25.03 2012	26-29.03 2012	30.03	31.03
	Craiova-T.Mag.	Iernut-Sibiu God-Levice Tisz./Kis.-Muk	Urech.-Domn.		Rosiori-Muk.	V.Kap.-Muk.	Arad-Timis. Sajosz.-Muk. Beogr.-Obren.	Rosiori-Oradea	Burst.-Muk.
RO=>HU	350						250		350
HU=>RO	550	400		550	400	550		400	
RO =>RS	650						600		650
RS =>RO	400	350		400	350	400		350	
RO =>BG	350								
BG =>RO	350								
RO=>UA	50				0	50			
UA =>RO	150	100		150	0	150		100	
RO Export	1400				1350	1400	1250		1400
RO Import	1450	1200		1450	1100	1450		1200	

- TRM export/import in interfata RO 300 MW / 300-400 MW

- TRM export in interfata RO+BG 300 MW

Limite**Export :**

- dec. LEA 400kV Nis-Sofia V -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
- dec. LEA 400kV Djerdap-Bor -> 100-102% TC LEA 400kV Tantareni-Kozlodui

26-30.03

- dec. LEA 400kV Arad-Mintia -> 100-105% TC LEA 220kV Timisoara-Sacalaz

Import

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori

05-14.03

- dec. LEA 400kV Rosiori-Mukacevo -> 100-105% LEA 110kV Chis.Cris-CET Arad

19-23.03

- dec. LEA 400kV Iernut-Sibiu -> 105-110% LEA 110kV Chis.Cris-CET Arad