

NTC pentru Septembrie 2012 _V3z (alocare zilnica/ intra-zi)

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1370MW (900MW +470MW);
- Limita pe L400kV Portile de Fier-Djerdap **1300 A** (Djerdap); reglaje de **vara** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1000MW,Turcia import 150MW, HU import initial 1800MW, RS import initial 310MW,;
- Export initial RO 500MW, BG 650 MW
- Masuri preventive si post-event. Schimburi pronozate; fara soldare; conventii bilaterale.
- Capacitate de import suplimentara datorata punerii in functiune a AT400/220kV lernut.

Valorile NTC fiabile pe granitele Romaniei in **Septembrie 2012** sunt :

NTC	01-02.09 2012	03-07.09 2012	08-09.09 2012	10-12.09 2012	13-14.09 2012	15-16.09 2012	17.09. 2012	18-20.09 2012	21.09 2012	22-23.09 2012	24-27.09 2012	28-30.09 2012
	Gutinas-Brasov			Tantarenii-Sibiu					Rahman-Dobrudja			
		AT Rosiori			AT1 PdF					AT2 PdF		
		Nis-Kos.			Isaccea-Va			A.Iulia-Has		Nis-SofiaV		
		c2PdF-Res			Jagodina-Krag.			Obrenovac-Krag.		N.Santa-B.		ClujF-lernut
				Gadalin-Cluj Est								
RO=>HU	400		350						300		350	a
HU=>RO	700	250	600	500	600		700		600		700	a
RO =>RS	400		350						300		350	a
RS =>RO	250		350									a
RO =>BG	250											a
BG =>RO	400	300	400			300				250		a
RO=>UA	50											
UA =>RO	100											
ROExport	1150		1050			1000			900		1000	
ROImport	1450	900	1350	1450					1350		1400	

- TRM export/import in interfata RO **300 MW / 400 MW**

- TRM export in interfata RO+BG **300 MW**