

16.

**NTC pentru Mai 2011 \_V6 : Fara retragerea LEA 400kV Mintia-Sibiu si LEA 220kV Mintia-Timisoara**  
**Pif LEA 400kV Isaccea-Varna 27.05.2011**  
**Fara retragerea LEA 400kV 1+2 Tantareni-Kozlodui in perioada 23-27.05.2011**

**Luand in considerare :**

- Generatie initiala in CHE Portile de Fier 950 MW ;
- Limita pe L400kV Portile de Fier-Djerdap 1600 A ( TC Portile de Fier);
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Reglaje de vara la protectii in Serbia ;
- Masuri preventive si post-event;
- Schimburi prognozate si variante de schimb; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Mai 2011** sunt :

NTC	01.05 2011	02-06.05 2011	07-08.05 2011	09-13.05 2011	14-15.05 2011	16-20.05 2011	21-22.05 2011	23-27.05 2011	28-29.05 2011	30-31.05 2011
		Iernut-Sibiu		Mintia-Sibiu		Mintia-Tim.		Tint.-Ko.1+2	Pif Isaccea-Varna	LEA RS
	LEA UA		U2 ONE							
				LEA BG						
RO=>HU	450	400			450			350		300
HU=>RO	700	500	700							
RO =>RS	550									
RS =>RO	200			500				500		300
				250				200		150
RO =>BG	300			200				300		250
BG =>RO	300			400				300		
RO =>UA	50									
UA =>RO	200	100	200					150	200	250
ROExport	1350	1300		1150		1200		1300	1200	900
ROImport	1400	1100	1400	1550		1400		1400		

- TRM export/import in interfata RO 300 MW / 400 MW
- TRM export in interfata RO+BG 300 MW