

NTC pentru Mai 2011 _V3 : Fara retragerea LEA 400kV Mintia-Sibiu si LEA 220kV Mintia-Timisoara

Luand in considerare :

- Generatie initiala in CHE Portile de Fier 950 MW ;
- Limita pe L400kV Portile de Fier-Djerdap 1600 A (TC Portile de Fier);
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Reglaje de vara la protectii in Serbia ;
- Masuri preventive si post-event;
- Schimburi prognozate si variante de schimb; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Mai 2011** sunt :

NTC	01.05 2011	02-06.05 2011	07-08.05 2011	09-13.05 2011	14-15.05 2011	16-20.05 2011	21-22.05 2011	23-27.05 2011	28-29.05 2011	30-31.05 2011
		Iernut-Sibiu		Mintia-Sibiu			Mintia-Tim.			
		U2 CNE						Tint.- Ko.1+2		Tint.-Ko.1+2
	LEA UA			LEA BG						LEA RS
RO=>HU	450	400				450		300		
HU=>RO	700	500	700							
RO =>RS	550			500				250		
RS =>RO	200			250				200		150
RO =>BG	300			200		300		250		
BG =>RO	300			400		300				
RO =>UA	50									
UA =>RO	200	100	200			150		200		250
ROExport	1350	1300		1150		1200		1300		850
ROImport	1400	1100	1400	1550				1400		

- TRM export/import in interfata RO **270-300 MW / 400 MW**

- TRM export in interfata RO+BG **300 MW**