

V6.7

**NTC pentru Mai 2011 _V6 : Fara retragerea LEA 400kV Mintia-Sibiu si LEA 220kV Mintia-Timisoara
Pif LEA 400kV Isaccea-Varna 27.05.2011
Fara retragerea LEA 400kV 1+2 Tantareni-Kozlodui in perioada 23-27.05.2011**

Luand in considerare :

- Generatie initiala in CHE Portile de Fier 950 MW ;
- Limita pe L400kV Portile de Fier-Djerdap 1600 A (TC Portile de Fier);
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Reglaje de vara la protectii in Serbia ;
- Masuri preventive si post-event;
- Schimburi prognozate si variante de schimb; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granițele Romaniei in **Mai 2011** sunt :

NTC	01.05	02-06.05	07-08.05	09-13.05	14-15.05	16-20.05	21-22.05	23-27.05	28-29.05	30-31.05
	2011	2011	2011	2011	2011	2011	2011	2011	2011	2011
		Iernut-Sibiu	U2 CNE	Mintia-Sibiu		Mintia-Tim.		Timt.-Kozl+2	Pif Isaccea-Varna	Timt.-Kozl+2 LEA RS
RO=>HU	450	400				450				
HU=>RO	700	500	700					350		300
RO=>RS	550			500				500		300
RS=>RO	200			250				200		150
RO=>BG	300			200			300	300		250
BG=>RO	300			400			300			
RO=>UA	50									
UA=>RO	200	100	200				150	200		250
ROExport	1350	1300		1150		1200	1300	1200		900
ROImport	1400	1100	1400	1550			1400			

- TRM export/import in interfata RO 300 MW / 400 MW
- TRM export in interfata RO+BG 300 MW