

## NTC pentru Noiembrie 2011\_V4 :

### Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1400MW (850MW + 550MW);
- Limita pe L400kV Portile de Fier-Djerdap 1600 A ( PdFier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1200MW, Turcia 300MW, HU 620MW;
- Export initial BG 700 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Noiembrie 2011** sunt :

NTC	01-04.11 2011	05.11 2011	06.11 2011	07-11.11 2011	12-13.11 2011	14-18.11 2011	19-20.11 2011	21-25.11 2011	26-27.11 2011	28-30.11 2011
	1c Resi.-Tim. Tant.-Bradu Kisvar.-Muk.	Mucacevo-Burstyn	Arad-Sand. Stejar-Gheo. Tisalak-Muk.	Arad-Mintia Stejar-Dum.	1c PdF-Res. G.lal-L.Sarat Krizov.-VDur					1cPdF-Res. Buc.S-G.lal Leme.-VKap.
RO=>HU	400	500	550	450	550	450	550	250	350	
HU=>RO	450	600		500		400	500	550	500	700
RO =>RS	550		650			600	690	500	600	
RS =>RO	350		400			350	400			
RO =>BG	325			250						
BG =>RO	325			250						
RO=>UA	50									
UA =>RO	100	150		100				150	100	200
ROExport	1325	1425	1575	1400	1500	1350	1540	1050	1250	
ROImport	1225	1425	1475	1250		1100	1250	1350	1250	1550

- TRM export/import in interfata RO 300 MW / 400 MW

- TRM export in interfata RO+BG 300 MW

**Limite****Export :**

- dec. LEA 400kV Tanatreani-Kozlodui -> 100% TC LEA 400kV Portile de Fier-Djerdap
- dec. LEA 400kV Nis-Sofia V -> 100% TC LEA 400kV Portile de Fier-Djerdap

**01-04.11:**

- + LEA 400kV Portile de Fier-Djerdap -> 110% TC LEA220kV Resita-Timisoara (1c) + redispeserizare post-event

**21-25.11+28-30.11:**

- + LEA 400kV Portile de Fier-Djerdap -> 110% TC LEA220kV Portile de Fier-Resita + redispeserizare post-event (sau automatica P LEA 220kV)

**Import**

- dec. LEA 400kV Rosiori-Gadalin -> 100% AT 400/220kV Rosiori