

NTC pentru Octombrie 2011 _V3 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1500MW (950MW + 550MW);
- S4 710MW
- Limita pe L400kV Portile de Fier-Djerdap 1600 A (PdFier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate; automatici pe AT PdFier;
- Import initial GR+MK+AL 1050MW, Turcia 300MW, HU 700MW;
- Export initial BG 600 MW
- Masuri preventive si post-event. Schimburii prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Octombrie 2011** sunt :

NTC	01.10 2011	02.10 2011	03-05.10 2011	06-07.10 2011	08-09.10 2011	10-14.10 2011	15-16.10 2011	17-21.10 2011	22-23.10 2011	24-28.10 2011	29-30.10 2011	31.10 2011
	Jag-Krag		Sajo-Muk			CMog-Stip	Burst-Muk	Isac-Tulcea			Burst-Muk	
RO=>HU	450			400	450	400	500	400	500	450	500	
HU=>RO	300	350	400	450	400	450	550	300	450		550	500
RO =>RS	600					550	600	700	600			
RS =>RO	300			350				200	350			
RO =>BG	250						200					275
BG =>RO	250						200					275
RO=>UA	50							0	50			
UA =>RO	100							0	100			
ROExport	1350			1300	1350	1250	1350	1300	1350	1300	1425	
ROImport	950	1000	1050	1150	1100	1150	1200	700	1100	1275	1225	

- TRM export/import in interfata RO 300 MW / 300-400 MW

- TRM export in interfata RO+BG 300 MW

- S4 ≤ 780 MW; 17-21.10: S4 ≤ 700 MW

a

a

a

a

a

a

Limite

Export :

- dec. LEA 400kV Tanatreni-Kozlodui -> 100% TC LEA 400kV Portile de Fier-Djerdap 10-14.10
- dec. LEA 400kV Nis-Sofia V -> 100% TC LEA 400kV Portile de Fier-Djerdap 17-28.10
- + dec. AT1 Timisoara -> 100% TC LEA220kV Timisoara-Sacalaz
- dec. C1 220kV Resita-Timisoara -> 100% TC c2 220kV Resita-Timisoara

Import

- dec. LEA 400kV Rosiori-Gadalin -> 100% AT 400/220kV Rosiori
- dec. AT 400/220kV Rosiori -> 100% AT 400/220kV Iernut 01-05.10
- + dec. LEA 400kV Rosiori-Mukacevo -> 100% TC LEA 220kV A. Julia-Mintia 17-21.10
- dec. LEA 400kV Iernut-Sibiu -> 105% (25°) LEA 110kV Arad-Ch. Cris