

NTC pentru Septembrie 2011 _V1 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1540MW (850MW + 690MW);
- S4 610MW
- Limita pe L400kV Portile de Fier-Djerdap 1300 A (Djerdap); reglaje de vara la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita in funct. la retragerea unei LEA 400kV Portile de Fier sau Djerdap; automatici pe AT PdFier;
- Import GR+MK+AL 1300MW ; import Turcia 250MW; import HU 1230MW;
- Export initial BG 600 MW
- Masuri preventive si post-event (buclari in 110kV, redispecerizare). Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Septembrie 2011** sunt :

NTC	01-02. 09. 2011	03. 09. 2011	04. 09. 2011	05. 09. 2011	06-09. 09. 2011	10. 09. 2011	11. 09. 2011	12-16. 09. 2011	17. 09. 2011	18. 09. 2011	19-20. 09. 2011	21. 09. 2011	22-23. 09. 2011	24. 09. 2011	25. 09. 2011	26-30. 09. 2011	
RO=>HU	300										250			350			
HU=>RO	700	400	250	200	350		500	250	500	650	350	250	350	450		350	
RO =>RS	500			450				400	500		400	450	400		450		
RS =>RO	350		200		300		100			300							
RO =>BG	300														200		
BG =>RO	300				350			300									200
RO=>UA	50																
UA =>RO	200	100						150			100						
ROExport	1150			1100				1050	1150		1000	1050	1000		1050		
ROImport	1550	1150	850	800	850	1100	1050	750	1050	1200	850	750	850	1050	1150	950	

- TRM export/import in interfata RO **200-300 MW / 400 MW**
- TRM export in interfata RO+BG **300 MW**