

NTC pentru Aprilie 2012_V4z :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1800MW (900MW +900MW);
- Limita pe L400kV Portile de Fier-Djerdap 1600 A (PdFier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1100MW, Turcia 50MW, HU 1065MW, RS 190MW;
- Export initial RO 600MW, BG 400 MW
- Masuri preventive si post-event. Schimburi prognozate, fara soldare; conventii bilaterale.
- Amanarea retragerii simultane a LEA 220kV Arad-Timisoara si Arad-Calea Aradului in mai 2012 si a LEA 400kV Isaccea-Dobruja dupa 15 Aprilie.

Valorile NTC fiabile pe grantele Romaniei in **Aprilie 2012**, cu reevaluarea perioadei 09-22 Aprilie, sunt :

NTC	01.04 2012	02-06.04 2012	07-08.04 2012	09-12.04 2012	13-15.04 2012	16-20.04 2012	21-22.04 2012	23-26.04 2012	27-29.04 2012	30.04 2012
		Arad-Timisoara +Arad-CARAD					Arad-Baba Domn.-Brazi Isaccea-Dobr.	Tant.-Urec.	Stejaru-Gheo.	
	Burst.-Muk. Beograd-Obr.			Isaccea-Debr						BaiaM-Tihau AT1 Timis.
										Albert.-Zukr.
RO=>HU	400									
HU=>RO	300						350			
RO =>RS	600				650					
RS =>RO	300									
RO =>BG	300	350		350		300				
BG =>RO	250	300		300				200		
RO=>UA	50									
UA =>RO	100									
RO Export	1350	1400		1400	1450	1400				
RO Import	950	1000		1000			1050	950		

- TRM export/import in interfata RO 300 MW / 400 MW

- TRM export in interfata RO+BG 300 MW

Limite

Export :

- dec. LEA 400kV Tantareni-Kozlodui -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
 - dec. LEA 400kV Nis-Sofia V -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
 - dec. LEA 400kV Djerdap-Bor -> 100-102% TC LEA 400kV Tantareni-Kozlodui
- 02-12.04**
- dec. LEA 400kV Arad-Mintia -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
- 23-27.04+40.04**
- dec. AT2 220/110kV Timisoara -> 100-105% TC LEA 220kV Timisoara-Sacalaz

Import

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori