

NTC pentru August 2012_V0 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1620MW (900MW +720MW);
- Limita pe L400kV Portile de Fier-Djerdap **1300 A** (Djerdap); reglaje de **vara** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1040MW, Turcia import 350MW, HU import initial 2350MW, RS import initial 600MW.;
- Export initial RO 500MW, BG 800 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **August 2012** sunt :

NTC	01-03.08	04-05.08	06-08.08	09-10.08	11-12.08	13.08	14.08	15.08	16.08	17.08	18.08	19.08	20.08	21-24.08	25-26.08	27-28.08	29-31.08	
	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	
	T Arad			Buc.S-Domnesti									Paroseni-Tg.Jiu					PdF-Dje
	Bor-Nis	Djerdap-Drimno	Mintia-Sibiu BMare-Iernut				Beo-Drm	Nis-Jagodina				Djerdap-Bor		ClujE-Gadalin				
	Burshtyn-Mukacevo Mizia-Tsarevets													Brasov-Gutinas				Muk.-VKap
RO=>HU	300	350	250			400						350	250			350	450	a
HU=>RO	700												650	500	700			a
RO =>RS	350	300				400						350	250			300	0	a
RS =>RO	300	250				300						150					0	a
RO =>BG	250																	a
BG =>RO	300																	a
RO=>UA	50																	
UA =>RO	200											250	100	100	250			
ROExport	950	950	850			1100						1000	800			950	750	
ROImport	1500	1450				1500						1400	1200	1050	1400		1250	

- TRM export/import in interfata RO 200-300 MW / 300-400 MW

- TRM export in interfata RO+BG 300 MW

Limite

Export :

01-03.08 + 19-28.08:

- dec. LEA 400kV Tantareni-Kozlodui
- dec. LEA 400kV Nis-Sofia V

01-03.08 +

- dec c1 220kV Resita-Timisoara

20-26.08 +

- dec c1 220kV Portile de Fier-Resita
- Redispecerizare preventiva** : in funct. CET Paroseni sau CHE Hasdat sau limitare CHE PdFier+Djerdap.

04-13.08:

- dec c1 220kV Portile de Fier-Resita
- dec. LEA 400kV Djerdap-Bor

14-18.08:

- dec. LEA 400kV Tantareni-Kozlodui
- dec. LEA 400kV Nis-Sofia V

29-31.08:

- dec c1 220kV Portile de Fier-Resita

Import

- dec. LEA 400kV Rosiori-Gadalin

06-15.08 +

- dec. LEA 400kV Rosiori-Mukacevo

19.08 + 27-28.08 +

- dec. LEA 400kV Rosiori-Mukacevo

20-24.08 + :

- dec. AT 400/220kV Rosiori

25-26.08 +

- dec. c2 220kV Iernut-Ungheni

- > 100% AT220/110kV Iernut