

NTC pentru Decembrie 2012_V1 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1427MW (700MW +727MW);
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1200MW, Turcia import 50MW, HU import initial 1050MW, RS import initial 720MW.;
- Export initial RO 500MW, BG 650 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe grantele Romaniei in **Decembrie 2012** sunt :

NTC	01-02.12	03-04.12	05-06.12	07.12	08-09.12	10-16.12	17.12	18.12.2012	19-20.12	21-22.12	23-31.12
	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012	2012
	G.Ial-L.Sar	Isaccea-Varna	A.Iulia-Cluj F.	Lemesani-V.Kapusany	Iernut-Sibiu*	Nosovice-Varin					LEA SK
RO=>HU	500	550									
HU=>RO	250	350			200			250			
RO =>RS	500		550								
RS =>RO	250	300			150			200			
RO =>BG	250										
BG =>RO	250										
RO=>UA	50										
UA =>RO	100										
ROExport	1300	1350	1400								
ROImport	850	1000			700			800			

- TRM export/import in interfata RO 300 MW / 400 MW

- TRM export in interfata RO+BG 300 MW

* S4 ≤ 630-700MW

a
a

a
a

a
a

Limite

Export :

- dec. LEA 400kV Tantaraeni-Kozlodui -> 100-102% LEA 400kV Portile de Fier-Djerdap (Djerdap)
- dec. LEA 400kV Nis-Sofia V -> 100-102% LEA 400kV Portile de Fier-Djerdap

Import

01-07.12+18-31.12

- dec. LEA 400kV Rosiori-Gadalini -> 100-103%AT 400/220kV Rosiori +**S4≤1000MW**
- dec. AT 400/220kV Iernut -> 100-103%AT 400/220kV Rosiori

08-17.12

- dec. LEA 400kV Rosiori-Mukacevo -> LEA 110kV C.Arad-Ch.Cris 110-112% (Itermic 20°)
+**S4≤ 630-700MW**: redispecerizare preventiva CTE Iernut 0->170MW+CHE Mariselu 70->210MW (sau CHE Mariselu 70->140MW+CHE Galceag 0->70MW)