

## NTC pentru Iulie 2012\_V1 :

### Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1400MW (750MW +650MW);
- Limita pe L400kV Portile de Fier-Djerdap 1300 A ( Djerdap); reglaje de vara la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1070MW, Turcia import 50MW, HU import initial 1510MW, RS import initial 190MW.;
- Export initial RO 500MW, BG 750 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in Iulie 2012 sunt :

NTC	01.07 2012	02-03.07 2012	04-05.07 2012	06.07 2012	07-08.07 2012	09-11.07 2012	12-13.07 2012	14-15.07 2012	16-18.07 2012	19-20.07 2012	21-22.07 2012	23-26.07 2012	27.07 2012	28-29.07	30-31.07 2012
	Tant- Slatina									AT1 Iernut		Pance- Drn			Bor-Nis
RO=>HU	400				350		400	350				400		350	300
HU=>RO	650	450	500		650		550			450		600		650	
RO =>RS	400											450		400	300
RS =>RO	300			400											
RO =>BG	200														
BG =>RO	300														
RO=>UA									50						
UA =>RO	150	100			150		100	150	100	100				150	
ROExport	1050		1000				1050	1000				1100		1000	850
ROImport	1400	1150	1200	1300	1500		1350	1400	1400	1250		1300		1500	

- TRM export/import in interfata RO 300 MW / 400 MW
- TRM export in interfata RO+BG 300 MW

**Limite****Export :**

- dec. LEA 400kV Tantareni-Kozlodui -> 100-102% LEA 400kV Portile de Fier-Djerdap (Djerdap)
- dec. LEA 400kV Nis-Sofia V -> 100-102% LEA 400kV Portile de Fier-Djerdap

**30-31.07 : +**

- dec. LEA 400kV Tantareni-Kozlodui -> 105% LEA 400kV Djerdap-Drmno
- dec. LEA 400kV Nis-Sofia V -> 105% LEA 400kV Djerdap-Drmno

**Import**

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori

**19-22.07 :**

- dec. AT 400/220kV Rosiori -> 100-102% T 400/110kV Cluj Est +S4 ≤ 600MW