

## NTC pentru Martie 2012\_V1 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1600MW (700MW +900MW);
- Limita pe L400kV Portile de Fier-Djerdap 1600 A ( Pdfier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1100MW, Turcia import 40MW, HU import initial 720MW, RS import initial 210MW ;
- Export initial RO 400MW, BG 400 MW
- Masuri preventive si post-event. Schimburi prognozate, fara soldare; conventii bilaterale.

Valoriile NTC fiabile pe grantele Romaniei in **Martie 2012** sunt :

NTC	01-04.03 2012		05-11.03 2012		12-14.03 2012		15-16.03 2012		17-18.03 2012		19-23.03 2012		24-25.03 2012		26-29.03 2012		30.03		31.03	
	Craiova- T.Mag.		Iernut-Sibiu		Urechn.-Domn.						Rosiori-Muk.		V.Kap.-Muk.		Saljosz.-Muk. Beogr.-Obren.		Rosiori-Oradea Burst.-Muk.			
RO=>HU	350		400		550		400		550		250		400		350					
HU=>RO	550		400		550		400		550		250		400		350					
RO =>RS	650																			
RS =>RO	400		350		400		350		400		600		350		650					
RO =>BG	300																			
BG =>RO	150																			
RO=>UA	50																			
UA =>RO	150		100		150		0		50		0		150		100					
RO Export	1350																			
RO Import	1250		1000		1250		1300		950		1300		1350		1200		1050		1350	

- TRM export/import in interfata RO 300 MW / 300-400 MW
- TRM export in interfata RO+BG 300 MW

## Limite

### Export :

- dec. LEA 400kV Nis-Sofia V -> 100-102% TC LEA 400kV Portile de Fier-Djerdap
- dec. LEA 400kV Djerdap-Bor -> 100-102% TC LEA 400kV Tantarani-Kozlodui  
**26-30.03**
- dec. LEA 400kV Arad-Mintia -> 100-105% TC LEA 220kV Timisoara-Sacalaz

### Import

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori  
**05-14.03**
- dec. LEA 400kV Rosiori-Mukacevo -> 100-105% LEA 110kV Chis.Cris-CET Arad  
**19-23.03**
- dec. LEA 400kV Iernut-Sibiu -> 105-110% LEA 110kV Chis.Cris-CET Arad