

## NTC pentru Octombrie 2012 \_V0 :

**Luand in considerare :**

- Programme de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1300MW (750MW +550MW);
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** ( TC Portile de Fier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1000MW, Turcia import 100MW, HU import initial 1580MW, RS import initial 390MW;
- Export initial RO 500MW, BG 600 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Octombrie 2012** sunt :

NTC	01-05.10 2012	06-07.10 2012	08-12.10 2012	13-14.10 2012	15-18.10 2012	19.10 2012	20-21.10 2012	22-23.10 2012	24-26.10 2012	27-28.10 2012	29-31.10 2012
<b>RO=&gt;HU</b>	<b>450</b>	<b>500</b>	<b>550</b>	<b>500</b>		<b>450</b>		<b>500</b>		<b>450</b>	a
<b>HU=&gt;RO</b>	<b>400</b>	<b>500</b>	<b>400</b>	<b>450</b>	<b>250</b>	<b>450</b>		<b>500</b>	<b>450</b>	<b>500</b>	a
<b>RO =&gt;RS</b>	<b>400</b>	<b>450</b>	<b>500</b>		<b>400</b>			<b>500</b>		<b>400</b>	a
<b>RS =&gt;RO</b>	<b>300</b>				<b>250</b>	<b>300</b>		<b>350</b>		<b>400</b>	a
<b>RO =&gt;BG</b>	<b>250</b>										a
<b>BG =&gt;RO</b>	<b>300</b>									<b>200</b>	a
<b>RO=&gt;UA</b>	<b>50</b>					<b>50</b>					
<b>UA =&gt;RO</b>	<b>100</b>		<b>0</b>				<b>100</b>				
<b>ROExport</b>	<b>1150</b>	<b>1250</b>	<b>1300</b>	<b>1150</b>		<b>1150</b>		<b>1300</b>		<b>1150</b>	
<b>ROImport</b>	<b>1100</b>	<b>1200</b>	<b>1000</b>	<b>1050</b>	<b>800</b>	<b>1050</b>		<b>1250</b>		<b>1200</b>	

- TRM export/import in interfata RO **300 MW / 400 MW**
- TRM export in interfata RO+BG **300 MW**