

NTC pentru Aprilie 2013 _V1 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1650 MW (750MW +900MW);
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR(+ITcc)+MK+AL 1150MW, Turcia import 50MW, HU import initial 1250MW, RS import initial 130MW.;
- Export initial RO 600MW, BG 650 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Aprilie 2013** sunt :

NTC	01-02.04 2013	03-04.04 2013	05.04 2013	06.04 2013	07.04 2013	08-12.04 2013	13-14.04 2013	15-19.04 2013	20.04 2013	21.04 2013	22.04 2013	23-26.04 2013	27.04 2013	28.04 2013	29-30.04 2013	
	Rahman-Dobrudja															
	Mintia-Alba Iulia										AT Urechesti					
	B.Mare-Rosiori c1			Gy-Ga		BM-Ros c2		BM-Iern			AT Iernut					
	Burs-Muk	Albertirsa-Z.Ukrainska														
	Melite-Bitola							Obrenov.-Krag.				Thess.-Dubr.			NS-Bab.	
	Initial S4 780 MW															
RO=>HU	600							450	600	550	600					
HU=>RO	600	400	500	550	600	500	300	500								
RO =>RS	600														550	
RS =>RO	450	350	400	450	350	250	350									
RO =>BG	200															
BG =>RO	250															
RO=>UA	50															
UA =>RO	100	150	100													
ROExport	1450							1300	1450	1400	1450	1400				
ROImport	1400	1100	1250	1350	1450	1200	900	1200								

- TRM export/import in interfata RO **300 MW / 400 MW**
- TRM export in interfata RO+BG **300 MW**

Limite

Export :

- dec. c1+2 400kV Tantareni-Kozlodui -> 100-101% LEA 400kV Portile de Fier-Djerdap (TC Portile de Fier)
- dec. LEA 400kV Nis-Sofia V -> 100-102% LEA 400kV Portile de Fier-Djerdap

15-19.04+22-26.04

- + dec. 1c 220kV Portile de Fier-Resita -> $\leq 105\%$ TC c2 Portile de Fier-Resita
+ reglaj ploturi AT 400/220kV Arad

Import

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori
- dec. LEA 400kV Rosiori-Mukacevo -> 105% LEA 110kV C.Arad-Ch.Cris (<Itermic 25)

22-26.04

- dec. AT 400/220kV Rosiori -> 100-102% T 400/110kV Cluj Est
+S4 \leq 740MW sau S4 \leq 780MW+con.T2 400/110kV Oradea