

NTC pentru Mai 2013 _V2 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1765 MW (900MW +865MW);
- Limita pe L400kV Portile de Fier-Djerdap **1300 A** (Djerdap); reglaje de **vara** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR(+ITcc)+MK+AL 1000MW, Turcia import 400MW, HU import initial 1950MW, RS export initial 18MW.;
- Export initial RO 500MW, BG 550 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Mai 2013** sunt :

NTC	01-03.05 2013	04-05.05 2013	06-07.05 2013	08-12.05 2013	13-17.05 2013	18-19.05 2013	20-24.05 2013	25-26.05 2013	27-31.05 2013
	Rahm-Do		ClujE-Gadalin		CArad-Sac.	Rosiori-Gadalin			
		Albertirsa-ZUkrainskaia			Tant.-Sibiu		Tant.-Sibiu		Hasd.-BaruM
		Albertirsa-Szolnok			Stupina-Varna & G.lalomitei-L.Sarat				
		Sajoseged-Mukacevo + Tisz.-Muk.						God-Levice	
	Rosiori-Vetis		Krizovany-VDur		Obrenovac-Beograd		Arad-CArad		
			Po-Tr		Blagoevgrad-Thessaloniki				
		1c Albertirsa-Mart.							
	Initial S4 740 MW							Bekescsaba-Szolnok	
RO=>HU	400		450		350	450	350	450	400
HU=>RO	250	200	250	200	350	200			
RO =>RS	400					450	400	450	400
RS =>RO	250	200	250	200	250	200			
RO =>BG	100								
BG =>RO	300	250	300			250			
RO=>UA	50								
UA =>RO	100								
ROExport	950		1000		900	1050	900	1050	950
ROImport	900	750	900	800	1000	750			

- TRM export/import in interfata RO **300 MW / 400 MW** ; TRM export in interfata RO+BG **300 MW**
- Import calculat cu conectarea T2 400/110kV Oradea & **S4≤740MW / S4≤600 MW +AT Rosiori ≤105% +redispecerizare post-event**
- Retragerea LEA 400kV Rosiori-Gadalin amanata dupa repunerea in functiune a LEA 400kV Sajoszeged-Mukacevo : 13.05 -> 18.05

Limite

Export :

- dec. c1+2 400kV Tantareni-Kozlodui -> 100-101% LEA 400kV Portile de Fier-Djerdap (Djerdap)
- dec. LEA 400kV Nis-Sofia V -> 100-102% LEA 400kV Portile de Fier-Djerdap

13-17.05 + 20-24.05 + 27-31.05

- + dec. 1c 220kV Portile de Fier-Resita -> $\leq 105\%$ TC c2 Portile de Fier-Resita
+ reglaj ploturi AT 400/220kV Arad

Import

01-17.05

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori

18-31.05

- dec. LEA 400kV Rosiori-Oradea -> 100-102% AT 400/220kV Rosiori