

NTC pentru Februarie 2015 _V2: licitatii lunare

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1322 MW (700 MW + 632 MW) ; 2 unitati in CNE; CEE 1400MW +CEF 380MW;
- Limita pe L400kV Portile de Fier-Djerdap **1600 A** (TC Portile de Fier); reglaje de **iarna** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL **1450MW**, export initial TR **150MW**, import initial HU **2150MW**, import initial RS **240MW**
Masuri preventive si post-avarie. Schimburi proghozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **Februarie 2015** sunt :

NTC	01-08.02.2015	09-15.02 2015	16-22.02.2015	23-27.02.2015	28.02.2015
RO=>HU	550	500	550		
HU=>RO	600	500		600	
RO =>RS	450		500		
RS =>RO	500	400		500	
RO =>BG	150				
BG =>RO	150				
RO=>UA	50				
UA =>RO	100				
RO Export	1200	1150	1250		
RO Import	1350^{2TO}	1250^{2TO}	1150^{2TO}	1350^{2TO}	1350

- TRM export/import in interfata RO **300 MW / 400 MW** ;
- AT Rosiori 105-106% + masuri, L 110kV CET Arad-Sofronea 100% (20°C) +masuri.
- Masuri postavarie : conectarea T Oradea in rezerva (2TO),
- Declansare L220kV Portile de Fier-Resita c1 => incarcare L220kV Portile de Fier-Resita c2 $\leq 120\% I_{nom_TC}$ (descarcare post-avarie)