

NTC pentru Ianuarie 2012_V0 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1350MW (840MW + 500MW);
- Limita pe L400kV Portile de Fier-Djerdap 1600 A (PdFier); reglaje de iarna la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 1250MW, Turcia export 300MW, HU import initial 610MW, RS import initial 510MW.;
- Export initial BG 450 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **ianuarie 2012** sunt :

NTC	01-15.01 2012	16-26.01 2012	27-31.01 2012
		AT4 Mintia c1 Mintia-Pestis	L Mintia-Hasdat c2 Mintia-Pestis
RO=>HU	350	450	
HU=>RO	400	550	450
RO =>RS	700		
RS =>RO	350	450	350
RO =>BG	350		
BG =>RO	350		
RO=>UA	50		
UA =>RO	150		
ROExport	1450	1550	
ROImport	1250	1500	1300

- TRM export/import in interfata RO 300 MW / 400 MW
- TRM export in interfata RO+BG 300 MW

Limite**Export :**

- dec. LEA 400kV Tanatreni-Kozlodui -> 100% TC LEA 400kV Portile de Fier-Djerdap
- dec. LEA 400kV Nis-Sofia V -> 100% TC LEA 400kV Portile de Fier-Djerdap

01-15.01:

- + LEA 400kV Portile de Fier-Djerdap -> 105-110% AT3400/220kV Mintia + redistribuzare post-event sau limitare productie Mintia

Import

- dec. LEA 400kV Rosiori-Gadalin -> 100% AT 400/220kV Rosiori
 - dec. AT 400/220kV Rosiori -> 100% AT 400/220kV Iernut
- S4=880MW (lim.stab.statica)