

15

NTC pentru Iunie 2011 _V5 : LEA 400KV Isaccea-Varna in functiune in perioadele cu:
LEA 400KV 1+2 Tantareni-Kozlodui deconectate (30.05-03.06)
LEA 400KV 1+2 Kozlodui-Sofia Vest deconectate (06-17.06)

Luand in considerare :

- Generatie initiala in CHE Portile de Fier si Dierdap 1615 MW (950 + 665 MW);
- Limita pe L400KV Portile de Fier-Dierdap 1300 A (Dierdap);
- Automatici de putere pe LEA 220KV Portile de Fier-Resita deconectate;
- Reglaje de vara la protectii in Serbia (LEA 400KV Dierdap-Bor-Nis 1740A, Dierdap-Drmno 1300A)
- Grecia import 500MW + export 500MW pe cablu IT (import sincron total 1000MW) ; Import GR+MK+AL 1700MW ;
- Export initial BG 700 MW;
- Masuri preventive si post-event;
- Schimburi prognozate; fara soldare; conventii bilaterale.

Valoriile NTC friabile pe granitiile Romaniei in Iunie 2011 sunt :

NTC	01-03.06	04-05.06	06-10.06	11-12.06	13-17.06	18-19.06	20-24.06	25-26.06	27-28.06	29-30.06
	2011	2011	2011	2011	2011	2011	2011	2011	2011	2011
	Tint.-ko.1+2		Rosiori-Muk		Mintia-Sibiu		Mintia-Tim.			
	U2 CNE		Tant.-Urech.				LEA RS			LEA RS
	LEA RS		LEA BG							LEA BG
	Isaccea-Varna con.		Isaccea-Varna con.							
RO=>HU	400						250	400		250
HU=>RO	700			650			700			
RO =>RS	300	500					250	420		
RS =>RO	220	270								
RO =>BG	300									
BG =>RO	300									
RO =>UA	50		0		50					
UA =>RO	200		0	200						
ROExport	1050	1250	1200	1250			850	1170		1020
ROImport	1420	1470	1270	1470	1420		1470			

- TRM export/import in interfata RO 300 MW / 300-400 MW
- TRM export in interfata RO+BG 300 MW