

## NTC pentru Septembrie 2011\_V2 :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Dierdap 1540MW (850MW + 690MW);
- S4 610MW
- Limita pe L400kV Portile de Fier-Dierdap 1300 A ( Dierdap); reglaje de vara la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita in funct. la retragerea unei LEA 400kV Portile de Fier sau Dierdap; automatici pe AT PdFier;
- Import GR+MK+AL 1300MW; import Turcia 250MW; import HU 1230MW;
- Export initial BG 600 MW
- Masuri preventive si post-event (bucari in 110kV, redispersizarea). Schimburi prognozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granițele Romaniei in **Septembrie 2011** sunt :

NTC	01-02. 09.2011	03. 09.2011	04. 09.2011	05. 09.2011	06-09. 09.2011	10. 09.2011	11. 09.2011	12-14. 09.2011	15-16. 09.2011	17. 09.2011	18. 09.2011	19-20. 09.2011	21. 09.2011	22.09. 2011	23.09. 2011	24. 09.2011	25. 09.2011	26-30. 09.2011
RO=>HU	300	400	250	200	350	500	250	500	650	350	250	250	350	350	450	350	350	350
HU=>RO	700	400	250	200	350	500	250	500	650	350	250	250	350	350	450	350	350	350
RO =>RS	500		200	450		300	100	400		500		400			300		450	
RS =>RO	350																	
RO =>BG	300									350								200
BG =>RO	300									350								200
RO=>UA	50																	
UA =>RO	200	100								150								
ROExport	1150			1100				1050		1150		1000	1050	1000	850	1050	1050	1050
ROImport	1550	1150	850	800	850	1100	1050	750	800	1100	1250	900	800	900	850	1050	1150	950

- TRM export/import in interfata RO 200-300 MW / 400 MW

- TRM export in interfata RO+BG 300 MW

- S4 < 610MW : 04-09.09 + 12-16.09 + 19-23.09 + 26-30.09