

NTC pentru Mai 2012_V4z :

Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1800MW (900MW +900MW);
- Limita pe L400kV Portile de Fier-Djerdap **1300 A** (Djerdap); reglaje de **vara** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita deconectate;
- Import initial GR+MK+AL 900MW, Turcia import 100MW, HU import initial 1550MW, RS import initial 74MW.;
- Export initial RO 400MW, BG 400 MW
- Masuri preventive si post-event. Schimburi prognozate; fara soldare; conventii bilaterale.
- Reducerea initiala a NTC BG->RO cu 150-50-150MW, la valorile ESO-EAD

Valorile NTC fiabile pe grantele Romaniei in **Mai 2012**, cu reevaluarea perioadei 14-20 Mai 2012, sunt :

| NTC | 01-04.05 2012 | 05-06.05 2012 | 07-11.05 2012 | 12-13.05 2012 | 14-16.05 2012 | 17-18.05 2012 | 19-20.05 2012 | 21-25.05 2012 | 26-27.05 2012 | 28-30.05 2012 | 31.05 2012 |
|-----------|---------------------------------------|------------------|------------------|------------------|------------------|------------------|-----------------------------|------------------|------------------|------------------|-------------------------------|
| | Isaceea-Rahm-Dobrudja Baia M-Tihau | Pif mai devreme | | | | | Arad-Timis. + Arad-CArad | | | | |
| | U1 CNE | | | | | | | | | | |
| | Cernav.-Pel. | Const.-Tariv. | Cernav.-Med. | Cernav.-Const | Buc.S-G.Ial. | | | G.Ial-L.Sarat | | | |
| | Marita-Plovid | Barbosi-Foc.V | -Gutinas | | AT400 Urech. | | | | | | |
| | Albert.-ZUkr. | Blagoev.-Thess | | | | | | Uros.-Skopje | | | Kosovo-Uros. Safa-Subotica |
| RO=>HU | 350 | | | | | | | | | | |
| HU=>RO | 600 | | | | | | | | | 450 | 300 |
| RO =>RS | 300 | | 350 | | | | | | | | |
| RS =>RO | 350 | | | | | | | 300 | | | |
| RO =>BG | 350 | | 350 | | 300 | | | | | | |
| BG =>RO | 300 | | 350 | | 350 | | 250 | 200 | | | |
| RO=>UA | 50 | | | | | | | | | | |
| UA =>RO | 200 | | | | | | | | | 150 | 100 |
| RO Export | 1050 | | 1100 | | 1050 | | | 1000 | | | 950 |
| RO Import | 1450 | | 1500 | | 1500 | | 1400 | 1350 | | 1150 | 1100 |

- TRM export/import in interfata RO 300 MW / 400 MW

- TRM export in interfata RO+BG 300 MW

Limite

Export :

- dec. LEA 400kV Tantaraeni-Kozlodui -> 100-102% LEA 400kV Portile de Fier-Djerdap (Djerdap)
- dec. LEA 400kV Nis-Sofia V -> 100-102% LEA 400kV Portile de Fier-Djerdap
- dec. LEA 400kV Djerdap-Bor -> 105-110%% LEA 400kV Djerdap-Drmno

Import

- dec. LEA 400kV Rosiori-Gadalin -> 100-102% AT 400/220kV Rosiori