

## NTC pentru August 2013 \_V2 :

### Luand in considerare :

- Programe de retrageri in SEN si SE interconectate;
- Generatie initiala in CHE Portile de Fier si Djerdap 1425 MW (800MW +625MW);
- Limita pe L400kV Portile de Fier-Djerdap **1300 A** ( Djerdap); reglaje de **vara** la protectii in Serbia ;
- Automatici de putere pe LEA 220kV Portile de Fier-Resita conectate la retragerea unei LEA 400kV in Portile de Fier+Djerda sau LEA 400kV Bor-Nis;
- Import initial GR(+ITcc)+MK+AL 890MW,Turcia import 450MW, HU import initial 1900MW, RS export initial 732MW.;
- Export initial RO 500MW, BG 650 MW
- Masuri preventive si post-event. Schimburi proghozate; fara soldare; conventii bilaterale.

Valorile NTC fiabile pe granitele Romaniei in **August 2013** sunt :

NTC	01-02.08 2013*	03-04.08 2013*	05-07.08 2013	08-11.08 2013	12-13.08 2013	14-15.08 2013	16-18.08 2013	19-23.08 2013*	24-25.08 2013*	26-27.08 2013*	28.08 2013*	29-30.08 2013	31.08 2013
RO=>HU	400	450	350	500	400		500	450	600	500	600	550	
HU=>RO	450	500	400	550	400	450	550		450	650		450	a
RO =>RS	500		450		500				0		500		a
RS =>RO	350	400	350	450	400	450		500	450	0	500	450	a
RO =>BG	100												a
BG =>RO	250												a
RO=>UA	50												
UA =>RO	100												
ROExport	1050	1100	950	1100	1050		1150	1100	1250	650	750	1200	
ROImport	1150	1250	1100	1350	1150	1250	1350	1400	1250	1000		1500	1250

- TRM export/import in interfata RO **200-300 MW / 300-400 MW**

- TRM export in interfata RO+BG **300 MW**

\* automatici P LEA220kV PdFier-Resita1,2 in functiune